

POLK COUNTY FIRE RESCUE

FIRE PREVENTION INSPECTION REPORT



Occupant Name: School Building Inspection Date: 4/17/2019

Address: 2211 28th Street Northwest InspectionType: Existing Educational Occupancies

Suite: Inspected By: Joyce Brock

Insp. Result Location	Code Set	Code
Pass	FL NFPA 01 2015 Chapter 10 General Safety Requirements	10.11.1.1 - Address numbers must be legible and visible from street.
N/A	FL NFPA 101 12 Chapter 15 Existing Educational Occupancies	15.7.2.3 - Excerpt: Emergency egress drills shall be conducted as follows: (1)
Pass	FL NFPA 101 2015 Chapter 15 Existing Educational Occupancies	15.7.2.3 - Excerpt: Emergency egress drills shall be conducted as follows: (1)

Inspector Comments:

Emergency egress drills shall be conducted as follows:

- (1) Not less than one emergency egress drill shall be conducted every month the facility is in session, unless both of the following criteria are met:
- (a) In climates where the weather is severe, the monthly emergency egress drills shall be permitted to be deferred.
- (b) The required number of emergency egress drills shall be conducted, and not less than four shall be conducted before the drills are deferred.
- (2) All occupants of the building shall participate in the drill.
- (3) One additional emergency egress drill, other than for educational occupancies that are open on a year-round basis, shall be required within the first 30 days of operation.

NOTE: please record the amount of time it took to vacate the building.

Pass

FL NFPA 101 2015
Chapter 15 Existing Educational Occupancies

15.7.2.4 - Excerpt: All emergency drill alarms shall be sounded on the...

Inspector Comments: All emergency drill alarms shall be sounded on the fire alarm system.

You have passed your inspection. If you have any questions, please call our office. **No Violations noted at this time.**

Company Representative:

A/17/2019 9:36:48 AM
Signature valid only in mobile-eyes documents

Fran Phillips 4/17/2019



Inspector:

Joyce Brock 4/17/2019