



STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PRIVATE SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

Violation #19. Drinking Fountains  
No water fountains are present at facility. This must be replaced.  
CODE REFERENCE: Drinking Fountains. 6A-2.0040(7)(b). Drinking fountains of an approved, sanitary slant jet type shall be provided in a ratio not less than 1 per 100 occupants. In no case shall fountains be located in any toilet room. 468.3.5.1. Educational and ancillary facilities shall be provided with drinking fountains for all occupants.

Inspection Conducted By: Steven Meadows (29341)  
Inspector Contact Number: Work: (863) 578-2027 ex.  
Print Client Name: Kathy Box  
Date: 4/16/2020

Inspector Signature:

Handwritten signature of Steven D. Meadows.

Client Signature:

Handwritten signature of Kathy Box.