



04/19/22

Achievement Academy

716 E BELLA VISTA ST
LAKELAND, FL 33805

Inspection # 22485

Inspection Type Periodic

Property # 3176

Occupancy Type Existing Educational Occupancy (Annual)

Illumination of Means of Egress

| Regulation | Violation | Due Date |
|--|---|----------|
| 1) 1:14.13.2.1 | Required emergency lighting systems shall be tested in accordance with 14.13.2. | 05/22/23 |
| Compliance | | |
| Remark: Emergency light in Building B in need of service. | | |

Marking of Means of Egress

| Regulation | Violation | Due Date |
|---|--|----------|
| 2) 1:14.14.1.1 | Means of egress shall be marked in accordance with Section 14.14 where required in Chapters 11 through 43 of NFPA 101. | 05/22/23 |
| Compliance | | |
| Remark: Old exit sign in Building C to be removed. | | |

Inspection History

Inspection Date

Status

Inspected By

04/19/22

Violations Found

Inspector BALDWIN



Inspector BALDWIN

Do not send payment.
All inspection fees are billed to your Lakeland Electric account.
If deficiencies are found, they shall be corrected immediately.

Thank you for supporting fire safety in our community.

Contact:

Phone:

Email: