

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PRIVATE SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #2. Playground
Protective outer layer of large playground equipment starting to break off, exposing rusted metal underneath. Equipment should be repaired to cover up rusted layers, or the equipment should be removed or replaced.
CODE REFERENCE: Playgrounds and Athletic Equipment. 6A-2.0040(2)(a)(c). Playgrounds shall be constructed & maintained to permit maximum utilization of sites with elimination of sanitary & health hazards including mudholes, fragments of glass, stone & similar obstructions. 468.2.2. Playground & equipment shall be safe, structurally sound, vermin proof, & shall not have jagged or sharp projections. Playground equipment shall be anchored to suitable foundations. Mats, wood chips, or sand shall be used under climbing equipment, slides, & swings.

Violation #11. Toilet Floor Drains
2 toilet student restroom was observed to not have a floor drain or adjacent hose bib. A floor drain must be installed or this restroom must be converted to a single occupant bathroom. A hose bib must be accessible nearby.
CODE REFERENCE: Toilet Floor Drains. 6A-2.0040(6)(a)1 and FBC 468.3.5.6. All group toilet rooms shall be provided with at least one (1) floor drain & (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Inspection Conducted By: Steven Meadows (29341)
Inspector Contact Number: Work: (863) 578-2027 ex.
Print Client Name: Tammy Bringger
Date: 10/29/2021

Inspector Signature:

Handwritten signature of Steven Meadows.

Client Signature:

Handwritten signature of Tammy Bringger.