

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PRIVATE SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #2. Playground
Chain link fasteners on swing set were observed to be very eroded and may break. This must be removed.
Excess chains on swing were observed on a swing, which may be a physical hazard when swinging. Excess chains must be removed.
Mulch is eroded away from climbing and swinging equipment. More mulch or other cushioning must be added to playground.
CODE REFERENCE: Playgrounds and Athletic Equipment. 6A-2.0040(2)(a)(c). Playgrounds shall be constructed & maintained to permit maximum utilization of sites with elimination of sanitary & health hazards including mudholes, fragments of glass, stone & similar obstructions. 468.2.2. Playground & equipment shall be safe, structurally sound, vermin proof, & shall not have jagged or sharp projections. Playground equipment shall be anchored to suitable foundations. Mats, wood chips, or sand shall be used under climbing equipment, slides, & swings.

Inspection Conducted By: Steven Meadows (29341)
Inspector Contact Number: Work: (863) 578-2027 ex.
Print Client Name: Tammy Bringger
Date: 11/9/2022

Inspector Signature:

Handwritten signature of Steven Meadows.

Client Signature:

Handwritten signature of Tammy Bringger.