



STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PRIVATE SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

Violation #5. Maintenance & Repair

In the classroom bathroom right next to main office, the sink water pressure is low. This must be fixed.

Several lightbulbs are out in the room where the kitchen is located. These must be replaced.

CODE REFERENCE: Maintenance & Repair. 6A-2.0040(3)(b)(c). Buildings shall be kept clean & in good repair, free from hazardous conditions, such as loose or broken floor tiles & boards; loose moldings; loose hanging fixtures, pipes, electric wires; & broken plaster. Furnishings & equipment shall be kept clean & in good repair, free of missing parts & sharp edges.

Inspection Conducted By: Rushil Kasetty (35264)  
Inspector Contact Number: Work: (863) 578-2039 ex.  
Print Client Name: Patti Miller  
Date: 1/9/2024

Inspector Signature:

Handwritten signature of Rushil Kasetty.

Client Signature:

Handwritten signature of Patti Miller.