

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PRIVATE SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #11. Toilet Floor Drains

No hose bib or floor drains were observed in the 2 student restrooms which had 2 toilets in each restroom. (No doors were on the stalls. These restrooms are used by pre-k to 5 year old ESE students). A hose bib within reach of the 2 restrooms is needed and a floor drain is needed in each group restroom. Another option is to remove a toilet in each restroom and convert to individual restrooms.

CODE REFERENCE: Toilet Floor Drains. 6A-2.0040(6)(a)1 and FBC 468.3.5.6. All group toilet rooms shall be provided with at least one (1) floor drain & (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Inspection Conducted By: Donna Salmon (29345)
Inspector Contact Number: Work: (863) 578-2006 ex.
Print Client Name: Tammy Bringger
Date: 11/6/2023

Inspector Signature:

Handwritten signature of Donna Salmon.

Client Signature:

Handwritten signature of Tammy Bringger.